

Scientific Equipment & Furniture Association

**SEFA 8M-2025**  
**Laboratory Grade Metal Casework Standard**

**SEFA World Headquarters**  
**1320 Main Street- Ste 300**  
**Columbia, SC 29201**

**Tel: 516-294-5424**  
**[www.sefalabs.com](http://www.sefalabs.com)**





## Table Of Contents

	Page	Page
<b>Committee Co-Chairs</b>	<b>1</b>	
<b>Foreword</b>		
<b>Sections</b>		
<b>1.0 Scope</b>	<b>3</b>	
<b>2.0 Purpose</b>	<b>3</b>	
<b>3.0 Definitions</b>	<b>3</b>	
<b>3.1 Description of Testing Apparatus</b>		
<b>4.0 Base Cabinets</b>	<b>6</b>	
<b>4.1 Description of Test Unit</b>		
<b>4.2 Cabinet Load Test</b>		
4.2.1 Purpose of Test		
4.2.2 Test Procedure		
4.2.3 Acceptance Level		
<b>4.3 Cabinet Concentrated Load Test</b>		
4.3.1 Purpose of Test		
4.3.2 Test Procedure		
4.3.3 Acceptance Level		
<b>4.4 Cabinet Torsion</b>		
4.4.1 Purpose of Test		
4.4.2 Test Procedure		
4.4.3 Acceptance Level		
<b>4.5 Cabinet Submersion Test</b>		
Not applicable to Metal Casework		
<b>4.6 Spill Containment Test</b>		
Not applicable to Metal Casework		
<b>5.0 Doors</b>	<b>8</b>	
<b>5.1 Door Hinge Test</b>		
5.1.1 Purpose of Test		
5.1.2 Test Procedure		
5.1.3 Acceptance Level		
<b>5.2 Door Impact Test</b>		
5.2.1 Purpose of Test		
5.2.2 Test Procedure		
5.2.3 Acceptance Level		
<b>5.3 Door Cycle Test</b>		
5.3.1 Purpose of Test		
5.3.2 Test Procedure		
5.3.3 Acceptance Level		
<b>6.0 Drawers</b>		<b>10</b>
<b>6.1 Drawer Static Test</b>		
6.1.1 Purpose of Test		
6.1.2 Test Procedure		
6.1.3 Acceptance Level		
<b>6.2 Drawer and Door Pull Test</b>		
6.2.1 Purpose of Test		
6.2.2 Test Procedure		
6.2.3 Acceptance Level		
<b>6.3 Drawer Impact Test</b>		
6.3.1 Purpose of Test		
6.3.2 Test Procedure		
6.3.3 Acceptance Level		
<b>6.4 Drawer Internal Impact Test</b>		
6.4.1 Purpose of Test		
6.4.2 Test Procedure		
6.4.3 Acceptance Level		
<b>6.5 Drawer Cycle Test</b>		
6.5.1 Purpose of Test		
6.5.2 Test Procedure		
6.5.3 Acceptance Level		
<b>7.0 Shelving</b>		<b>11</b>
<b>7.1 Description of Test Unit</b>		
<b>7.2 Shelf Load Test</b>		
7.2.1 Purpose of Test		
7.2.2 Test Procedure		
7.2.3 Acceptance Level		

## Table Of Contents (cont'd.)

	Page	Page
<b>8.0 Cabinet Surface Finish Tests</b>	<b>12</b>	
<b>8.1 Chemical Spot Test</b>		
8.1.1 Purpose of Test		
8.1.2 Test Procedure		
8.1.3 Acceptance Level		
<b>8.2 Hot Water Test</b>		
8.2.1 Purpose of Test		
8.2.2 Test Procedure		
8.2.3 Acceptance Level		
<b>8.3 Impact Test</b>		
8.3.1 Purpose of Test		
8.3.2 Test Procedure		
8.3.3 Acceptance Level		
<b>8.4 Paint Adhesion Test</b>		
8.4.1 Purpose of Test		
8.4.2 Test Procedure		
8.4.3 Acceptance Level		
<b>8.5 Paint Hardness Test</b>		
8.5.1 Purpose of Test		
8.5.2 Test Procedure		
8.5.3 Acceptance Level		
<b>8.6 Dart Impact Test</b>		
Not applicable to Metal Casework		
<b>8.7 Edge Delaminating Test</b>		
Not applicable to Metal Casework		
<b>8.8 Edge Impact Test</b>		
Not applicable to Metal Casework		
<b>8.9 Wear Resistance (Abrasion) Test</b>		
Not applicable to Metal Casework		
<b>9.0 Wall Cabinets, Counter Mounted and Tall Units</b>	<b>15</b>	
<b>9.1 Description of Test Unit</b>		
<b>9.2 Load Test</b>		
9.2.1 Purpose of Test		
9.2.2 Test Procedure		
9.2.3 Acceptance Level		
<b>10.0 Tables</b>	<b>16</b>	
<b>10.1 Description of Test Unit</b>		
<b>10.2 Load Test</b>		
10.2.1 Purpose of Test		
10.2.2 Test Procedure		
10.2.3 Acceptance Level		
<b>10.3 Table Racking Test</b>		
10.3.1 Purpose of Test		
10.3.2 Test Procedure		
10.3.3 Acceptance Level		
<b>11.0 Mobile Casework</b>	<b>17</b>	
<b>11.1 Description of Test Unit</b>		
<b>11.2 Static Stability Test</b>		
10.2.1 Purpose of Test		
10.2.2 Test Procedure		
10.2.3 Acceptance Level		
<b>11.3 Static Load Test</b>		
10.3.1 Purpose of Test		
10.3.2 Test Procedure		
10.3.3 Acceptance Level		
<b>11.4 Rolling Stability Test</b>		
10.3.1 Purpose of Test		
10.3.2 Test Procedure		
10.3.3 Acceptance Level		
<b>Endnotes</b>	<b>20</b>	
<b>Appendix 1</b>		
SEFA 8 Comparison Chart	<b>21</b>	
<b>Forms</b>	<b>22</b>	

## **SEFA 8-M Committee Co-Chairs**

**Andy Sinnamon - Mott Manufacturing**  
**[asinnamon@mott.ca](mailto:asinnamon@mott.ca)**

**Roy Richards - One Pointe Solutions**  
**[rrichards@onepointesolutions.com](mailto:rrichards@onepointesolutions.com)**

## Foreword

### SEFA Profile

The Scientific Equipment and Furniture Association (SEFA) is an international trade association comprised of manufacturers of laboratory furniture, casework, fume hoods and members of the design and installation professions. The Association was founded to promote this rapidly expanding industry and improve the quality, safety and timely completion of laboratory facilities in accordance with customer requirements.

### SEFA Standards

SEFA and its committees are active in the development and promotion of Standards having domestic and international applications. The Standards are developed by the association taking into account the work of other standard writing organizations. Liaison is also maintained with government agencies in the development of their specifications.

SEFA's Standards are developed in and for the public interest. These standards are designed to promote a better understanding between designers, architects, manufacturers, purchasers, and end-users and to assist the purchaser in selecting and specifying the proper product to meet the user's particular needs. SEFA's Standards are periodically updated. The Standards are numbered to include an annual suffix which reflects the year that they were updated. SEFA encourages architects to specify this document as follows: "SEFA 8M-2025".

### SEFA Glossary of Terms

SEFA has developed a Glossary of Terms (SEFA 4-2020) for the purpose of promoting a greater understanding between designers, architects, manufacturers, purchasers and end users. The terms defined by SEFA are frequently used in contracts and other documents, which attempt to define the products to be furnished or the work involved. The Association has approved this Glossary in an effort to provide uniformity among those who use these terms. Where a specific Standard contains definitions which differ from those in the Glossary of Terms, then the definitions in the specific Standard should be used.

SEFA encourages all interested parties to submit additional terms or to suggest any changes to those terms already defined by the Association. The definitions should be used to help resolve any disputes that may arise or to incorporate the applicable terms in any contract or related documents.

### SEFA Disclaimer

SEFA uses its best effort to promulgate Standards for the benefit of the public in light of available information and accepted industry practices. SEFA does not guarantee, certify or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with SEFA Standards or that any tests conducted under its Standards will be non-hazardous or free from risk. SEFA encourages the use of third party independent testing where appropriate.

**Note : Testing as described in this document must be performed and documented by a SEFA-approved third party testing facility. Visit us at [SEFALABS.COM](http://SEFALABS.COM) for the most current list of SEFA-approved test labs.**

## 1.0 Scope

The scope of this document is intended to provide manufacturers, specifiers, and users tools for evaluating the safety, durability, and structural integrity of metal laboratory grade furniture and complimentary items. This document is inclusive of casework (base cabinets, wall mounted cabinets, counter mounted cabinets, mobile base cabinets, tall cabinets), tables and shelving systems. Casework, tables and shelving manufactured for laboratory use should be subjected to the tests and procedures outlined below.

Metal laboratory grade casework shall consist of base cabinets, wall cabinets, counter mounted cabinets, tall cabinets, and shelving.

Aggregate test results may vary by manufacturer. Procedures for testing performance criteria shall be as outlined in this document and results made available upon request. It is assumed that the test model reflects the performance criteria for all products. However there may be certain door/ drawer configurations and/or sizes outside the test unit configuration identified that may not meet certain parts of this test. A test unit has been identified in this document with the sole purpose of obtaining continuity of procedures and results in a scientific format.

Great care should be exercised when heavy loads are applied to the cabinet and appropriate safety precautions taken to insure safety of testing personnel. Properly trained personnel should perform all tests. SEFA assumes no liability for damage or injury as a result of conducting these tests.

The acceptance levels are based on the cumulative field experience and laboratory testing of SEFA members based on actual needs of laboratories. This is a performance- based document. Specifications prescribing specific materials, hardware, finishes, workmanship or construction may or may not meet acceptance levels of this document. If prescriptive components of the specifications conflict with compliance of this document then the Architectural proscribed elements take precedent.

Testing as outlined in this document must be performed and documented by a SEFA-approved independent third party testing facility.

## 2.0 Purpose

The purpose of this document is to describe the distinguishing performance characteristics of metal laboratory grade furniture and complimentary items. Furniture shall be of a type specifically designed and manufactured for installation and use in a laboratory.

Although aggregate test results may vary from manufacturer to manufacturer, procedures for testing performance criteria shall be as outlined in this document and results made available upon request. It is assumed that the test model reflects the performance criteria for all products regardless of construction, size, or style used. A test unit has been identified in this document with the sole purpose of obtaining continuity for procedures and results in a scientific format.

## 3.0 Definitions

**Acceptance Levels** - The acceptance level for each performance criteria is based on the cumulative experience of actual field testing and laboratory results of SEFA members. Acceptance levels describe the expected outcome of each test procedure.

**ANSI/BIFMA** - ANSI is the American National Standards Institute. Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer. BIFMA is the Business and Institutional Furniture Manufacturer's Association, an association of manufacturers of desk products and the like.

**Apparatus** - A machine or group of machines and accessories.

**Arithmetic Mean** - A number obtained by dividing the sum of a set of quantities by the number of quantities in a set; average.

**ASTM** - American Society for Testing and Materials.

**Base Cabinets** - A base cabinet is a storage device consisting of two ends, a back, a face and may or may not include a top or top frame. The face may be open, to access the storage area, or may be outfitted with one or more drawers and/or doors. A base cabinet is always placed on the floor and normally supports a surface. The top surface is normally no more than 42" (1,067mm) off the floor surface.

**Best Practices** - When given a choice of grade, the "best practice" is to select one that offers a well defined degree of control over the quality of workmanship, materials, and installation of a project. SEFA-8 Standards are written from a view of high quality laboratory furniture.

**Cabinet Depth (Deep)** - Given a front, bottom, two sides, and a top, the cabinet depth is a measure of the side of the cabinet, in its normal upright position, from the outside back to the outside front excluding doors and door fronts.

**Cabinet Height (High)** - Given a front, bottom, two sides, and a top, the cabinet height is a measure of the side of the cabinet, in its normal upright position, from the bottom edge of the side to the top, excluding any surface.

**Cabinet Width (Wide)** - Given a front, bottom, two sides, and a top, the cabinet width is a measure of the front of the cabinet in its normal upright position from one side to the other.

**Casework** - Base and wall cabinets, display fixtures, and storage shelves. The generic term for both "boxes" and special desks, reception counters, nurses stations and the like. Generally includes the tops and work surfaces.

**Caster** - A small wheel on a swivel, set under a piece of furniture, a machine, etc., to facilitate moving it.

**Chase (Plumbing Area)** - Space located behind the back of the base cabinet used to house plumbing or electric lines.

**Combination Unit** - A base unit of the type that

has both door(s) and drawer(s).

**Counterbalance** - A device or weight incorporated into the cabinet body to prevent overturning when movable elements are extended.

**Counter Mounted Cabinet** - A counter mounted cabinet is a wall cabinet (usually with a height of approximately 48" [1,219mm] and is typically mounted on the work surface or shelf, as in a reagent shelf).

**Cupboard (Door Unit)** - That portion of the cabinet with no drawer(s) that may be enclosed by doors.

**Drawer** - A sliding storage box or receptacle opened by pulling out and closed by pushing in.

**Free Standing** - Requiring no support or fastening to other structures.

**Hardware** - Items such as screws, pulls, hinges, latches, locks, and drawer slides used in the construction of casework.

**High Density Shielding** - A barrier made of lead.

**Joinery** - The junction of two pieces intended to be permanently connected.

**Laboratory Cart** - A platform or multiple platforms with 4 wheels or casters designed and used to transport chemicals and/or instruments in laboratory and education settings. *(Currently not tested by SEFA)*.

**Laboratory Furniture** - Furniture designed and manufactured for installation and use in a laboratory.

**Latch** - A piece of hardware designed to hold a door closed.

**Leveling Screws (Levelers)** - Threaded components designed to allow adjustment of the cabinet vertically as needed for leveling.

**Mobile Base Cabinet** - A free standing storage cabinet mounted on casters specifically designed to be housed below an adjustable height bench/

table and for movement within the room or space for optimal reconfiguration and flexibility and not to be used for transporting chemicals or instruments.

**Mobile Tall Cabinet** - A free standing storage cabinet mounted on casters and capable of being readily moved or relocated. Mobile storage tall cabinets are designed for movement within a room or space for reconfiguration and flexibility and not to be used for transporting chemicals or instruments. (Currently not tested by SEFA)

**Movable Element** - An element that can be moved to protrude past the cabinet body, including but not limited to doors, drawers and pull-out shelves.

**Nominal Dimensions** - Not all cabinet manufacturers produce product to the identical dimensions. All dimensions given in this document are accurate to within five percent, which is considered nominal.

**Permanent Damage** - Destruction to material or joinery that would require repair in order to return to its original state.

**Permanent Deformation** - Deflection that has exceeded the limits of the product, thus changing the original shape of the product

**Permanent Deterioration** - Erosion or corrosion of material such that the component will never return to its original shape.

**Permanent Failure** - See "permanent damage."

**Pulls** - Articles of hardware used to grasp and open/close the door or drawer (see also hardware).

**Rack Resistance** - The ability of a product to resist stresses that tend to make the product distort and the drawers to become misaligned.

**Rail** - A horizontal member extending from one side of the cabinet to the other.

**Reagent** - A substance used because of its chemical or biological activity.

**Removable Back** - A panel located on the inside

back of the base cabinet, which is removable in order to gain access to utilities.

**Stainless Steel** - Iron based alloys containing more chromium than the 12% necessary to produce passivity (less reactive), but less than 30%.

**Submersion** - Covered with water.

**Tables** - An article of furniture having a flat, horizontal surface supported by one or more support members (legs), and a frame (apron).

**Tall Cabinet (Full Height Unit)** - A tall cabinet is a storage device that consists of two ends, a top and bottom panel, a back and a face. The face may be open to access the storage area or may be outfitted with one or more drawers and/or door(s). A tall cabinet is always placed on the floor and is nominally 84" (2,134mm) high.

**Torsion** - A force acting at a distance which tends to twist or rotate an object or cabinet.

**Uniformly Distributed** - A force applied evenly over the area of a surface.

**Unobstructed Entry** - A cabinet is deemed to be unobstructed if access to the entire storage area is completely without obstacle.

**Upright Position** - A cabinet oriented in its intended position.

**Wall Cabinet** - A wall cabinet is a storage device consisting of two ends, a back, a top, bottom, and a face. The face may be open to access the storage area or may be outfitted with one or more door(s). The wall cabinet usually does not include a drawer. A wall cabinet is always mounted on a vertical surface such as a wall, a divider, panel or some other vertical structure. A wall cabinet is usually less than 48" (1,219mm) high.

**Work Surface** - A normally horizontal surface used to support apparatus at a convenient height above the floor. Work surfaces are normally positioned atop a base cabinet or table structure.

### 3.1 Description of Testing Apparatus

**Solid Steel Bar** - A square solid steel bar 2 1/2" (63mm) square, 28 1/4" (717mm) long, weighing 50 pounds (22.679 Kg).

Sand or Shot Bag (10 pounds [4.545 Kg]) - A bag of plastic or cloth with the approximate dimensions 10 9/16" (268mm) x 11" (279mm) as in typical "gallon size re-closable storage bags." Filled with enough sand or shot so that contents weigh 10 pounds (4.545 Kg).

Sand Bag (20 pounds [9.071 Kg]) - Two 10 pound (4.545 Kg) sand bags bound together.

Shot Bag (100 lbs. [45.359 Kg]) - A plastic or cloth bag of sufficient size to contain 100 pounds (45.359 Kg) of shot.

Cycling Mechanism - Per ANSI BHMA 156.9.-2003


Steel Rod - A 2" (51mm) diameter by 12" (305mm) long rod, approximately 10 pounds (4.535 Kg) in weight.

Hot Water - To be considered "hot water," the temperature of the water must be between 190° F to 205° F (88° C to 96° C).

One Pound Ball - Solid steel sphere approximately 2" (51mm) in diameter.

Hardwood Corner Block - A block of hardwood 2" (51mm square) by 1" (25.4 mm) high.

Threshold - A 1/2" High x 4" Wide x 36" Long rectangular block with a 1/2" High x 1" Deep Bevel along each length. Material selected shall be substantial and not move or deform during the test, such as hardwood or poly.




## 4.0 Base Cabinets

### 4.1 Description of Test Cabinet

The base cabinet shall be a combination of cupboard and drawer per Figure 1. The base cabinet shall have nominal dimensions  $\pm 1"$  (25.4mm) of 48" (1,219.2mm) wide, 35" (889.0mm) high, and 22" (558.8mm) deep. The drawer shall be above the cupboard, full width and approximately one-fourth the height of the cabinet's face opening. The inside depth of the drawer shall be no less than 18" (457.2mm). The drawer in the full open position shall expose no less than 2/3 of the drawer interior. Cupboard shall be double-door design and provide unobstructed entry into the cabinet interior with the doors open. The unit shall contain one adjustable shelf. The cabinet back shall be the removable type (per manufacturer's standard design as used for access to the plumbing or chase area) with the removable panel removed.

The cabinet shall be free standing, squared and leveled and sitting 1" (25.4mm) off the floor on all four leveling screws. When leveling screws are not required, the cabinet shall be squared and leveled and sitting 1" (25.4mm) off the floor atop four hardwood corner blocks 2" (50.8mm) square and 1" (25.4mm) high. A top of 1" (25.4mm) thick 37-50 pcf medium density fiberboard shall be freely positioned on the cabinet without glue or fasteners of any kind. The top dimensions will be such that it will overhang the cabinet perimeter by 1" (25.4mm). Its weight shall be included in the test as live load. Before conducting the test,



a visual examination shall be conducted to verify that the unit configuration and setup conditions are appropriate. Operate doors and drawers. Doors should be free moving and latch properly. Inspect the unit for dimensions and note the fit of doors and drawers to the cabinet body. Open and close the drawer. The drawer should be free moving and function as specified by the manufacturer. Discontinue evaluation if unit is not in compliance or if malfunction is noted.

## 4.2 Cabinet Load Test -

### 4.2.1 Purpose of Test

The cabinet load test will challenge the structural integrity and load bearing capability of the cabinet construction. This test will demonstrate the ability of the cabinet to support heavy applied loads. This is not intended to test the functional characteristics of the cabinet under heavy loads.

### 4.2.2 Test Procedure

Verify that the cabinet is level and supported only by the levelers. Load the cabinet top by using 2000 pounds (907.2 Kg) of solid steel bars (per Section 3.1) stacked five high and spaced per Fig 2. After ten minutes, unload the cabinet.




Figure 2. Cabinet Load Test Configuration

### 4.2.3 Acceptance Level

The cabinet will have no signs of permanent failure. After the load is removed, inspect the levelers. Any deformation shall not interfere with the function of the leveling system.

## 4.3 Cabinet Concentrated Load Test

### 4.3.1 Purpose of Test

The purpose of this test is to challenge the functional characteristics of the cabinet when subjected to a concentrated load on the center of the cabinet top.

### 4.3.2 Test Procedure

Using solid weights or 10 pound (4.535 Kg) sand bags (per Section 3.1), apply a total of 200 pounds (90.718 Kg) to the top of the cabinet along the cabinet centerline (see Figure 3). Operate doors and drawers.




Figure 3 - Cabinet Concentrated Load Test

### 4.3.3 Acceptance Level

Door and drawer operation shall be normal under condition of test load. There shall be no signs of permanent deformation to front rail, cabinet joinery, doors, or drawers.

## 4.4 Cabinet Torsion

### 4.4.1 Purpose of Test

This test will evaluate the structural integrity of the cabinet construction when subjected to a torsional load.

### 4.4.2 Test Procedure

Measure the diagonal corners and record them as the pre-load baseline reference. The cabinet

shall be supported on all four corners with four inch square blocks located not more than 6 inches (152.4mm) in from each corner. Load the rear corner seven inches in from the corner at a 45 degree angle with 350 lbs. (158.757 Kg). Load the front corner seven inches in from the corner at a 45 degree angle with 200 lbs. (90.718 Kg). Carefully pick up the cabinet with a lift truck or similar device just off of the blocks and then remove the front left block under the 200 lbs. (90.718 Kg) and then resettle the cabinet on the remaining 3 blocks for a period of 24 hrs. After the 24 hr. period, repeat the last 3 steps in reverse order. After the unit has the load removed, the unit shall be re-measured on the same diagonal measurements with the difference recorded.




Figure 4. Base Cabinet Torsion Test Procedure

#### 4.4.3 Acceptance Level

When returned to normal position, the operation of the cabinet shall be normal, and there will be no permanent damage. The difference between the two measurements taken from measuring the diagonal corners shall be no more than 1/8" (3.175mm).

#### 4.5 Cabinet Submersion Test

**Not applicable to Metal Casework**

#### 4.6 Spill Containment Test

**Not applicable to Metal Casework**

### 5.0 Doors

#### 5.1 Door Hinge Test

##### 5.1.1 Purpose of Test

This test will demonstrate the durability of the door, door attachment and its hardware (hinge leaf, screws, etc.) to an applied load of 200 pounds (90.72 Kg).

##### 5.1.2 Test Procedure

Remove the shelf for this test. With unit and top set as described in Section 4.1, add sufficient weight to the top in order to prevent overturning. With cabinet door opened 90-degrees, hang a sling made up of two 100 pound (45.359 Kg) weights (shot bags or solid weights) over top of the door at a point 12" (304.8mm) out from the hinge centerline (see Figure 5). Slowly move door through two full cycles of the hinge at 160-degree arc. Remove weight and swing door through its full intended range of motion and close door.




Fig 5 Base Cabinet Door Load Configuration

### 5.1.3 Acceptance Level

The open door shall withstand a load of 200 pounds (90.72 Kg) when applied at a point 12"(304.8mm) from the hinge centerline without permanent damage. Operation of the door, after test shall show no significant permanent damage that will cause binding of the door or hinges or that will adversely affect operation of the catch.

### 5.2 Door Impact Test

#### 5.2.1 Purpose of Test

This test will demonstrate the resistance of a 240 inch-pound (27.1 N-m) impact to the door face. Only units that extend below the work surface should be subjected to this test. This test should not be inclusive of glass doors.

#### 5.2.2 Test Procedure

With unit and top set as described in Section 4.1, add sufficient weight to the top in order to prevent overturning. A 20 pound (9.07 Kg) sand bag (Section 3.1) shall be suspended and dropped to provide an impact of 240 inch-pounds (27.1 N-m) at the center of the closed door. (See Fig 6.)




Figure 6. Base Cabinet Door Impact Test Configuration

#### 5.2.3 Acceptance Level

After the test, the door and catch shall operate normally and show no signs of permanent damage. A dent or depression is an indication of

permanent damage. This test is not intended to evaluate the cabinet finish.

### 5.3 Door Cycle Test

#### 5.3.1 Purpose of Test

This test will demonstrate the durability of the door hinge hardware to withstand 100,000 cycles as a reliable measure for longevity).

#### 5.3.2 Test Procedure

Open the door 5 degrees. A cycling mechanism shall be used to operate the door 90 degrees from the 5 degree open position. The door shall operate for 100,000 cycles continuously, without hinge adjustment, at a speed of 15 cycles per minute.

#### 5.3.3 Acceptance Level

Door shall operate for the full cycle period without deterioration that will significantly affect the function of the door. The door shall operate freely without binding.

### 6.0 Drawers

#### 6.1 Drawer Static Test


##### 6.1.1 Purpose of Test

This test will demonstrate the ability to support a point load given to the front of the drawer and will challenge the drawer suspension system and the attachment of the drawer head to the drawer.

##### 6.1.2 Test Procedure

With unit and top set as described in Section 4.1, add sufficient weight to the top in order to prevent overturning. Open the drawer to 13" (330.2mm) of travel and hang 150 pounds (68.03 Kg) from the drawer head at the centerline of the drawer for five minutes. Remove the weight and operate the drawer through the full cycle.

**Fig. 7 Base Cabinet Drawer Static Load Test Configuration**



Note: Load top sufficient to prevent tipping of base cabinet. Weight shall be located at the back of the worksurface and centered.

### 6.1.3 Acceptance Level

There shall be no interference with the normal operation of the drawer and the drawer head should remain tightly fastened to the drawer.

## 6.2 Drawer and Door Pull Test

### 6.2.1 Purpose of Test


This test will evaluate the strength of the pull and pull hardware.

### 6.2.2 Test Procedure

Pulls are to be installed in accordance with manufacturer's practice using specified attaching hardware and method. Block door and drawer closed. Using a force gauge attached with a 1" (25.4mm) wide bracket (see Figure 8), apply a force of 50 pounds (22.68 Kg), for 15 seconds, perpendicular to each pull. Revise setup to apply force downward (see Figure 9).

### 6.2.3 Acceptance Level

Pulls shall resist force without breakage. After completion of test and removal of weight, there shall be no significant permanent deformation.



**Figure 8. Base Cabinet Door and Drawer Pull Horizontal Load Test Configuration**

## 6.3 Drawer Impact Test

### 6.3.1 Purpose of Test


This test will demonstrate the resistance to impact of the drawer bottom.

### 6.3.2 Test Procedure

Remove drawer; support each corner with 2"x2"x1" (50.8 x 50.8 x 25.4 mm) supports. Drop a 10 pound (4.545 Kg) sand or shot bag from a height of 24" (609.6 mm) into the bottom of the drawer at the center of the width of the drawer. Remove the sand or shot bag.

### 6.3.3 Acceptance Level

No damage or breakout of the drawer bottom.



**Figure 9. Base Cabinet Door and Drawer Pull Vertical Load Test Configuration**

## 6.4 Drawer Internal Rolling Impact Test

### 6.4.1 Purpose of Test

This test will evaluate the strength of the drawer head, bottom, and back as a result of opening and closing the drawer with a rolling load.

### 6.4.2 Test Procedure

Position the drawer on a table at a 45-degree angle per Figure 7. Place a 2" (50.8mm) diameter by 12" (304.8mm) long steel rod (approximately 10 pounds [4.545 Kg]) 13" (330.2mm) from the target impact area such that the rod will roll freely to impact the back of the drawer. Subject the back to three impacts and reverse the drawer to subject the front to three additional impacts.




Figure 10. Base Cabinet Drawer Internal Rolling Impact Test Configuration

### 6.4.3 Acceptance Level

The drawer shall show no permanent damage. All joinery shall be intact and the drawer, when replaced in the unit, shall operate normally. Minor scratches and dents are acceptable.

## 6.5 Drawer Cycle Test

### 6.5.1 Purpose of Test

This test is intended to replicate years of operation of a drawer under full load.

### 6.5.2 Test Procedure

Attach a bracket to the center of the drawer front by bolting it through the drawer front and body. Attach a cycling mechanism to the bracket using a free floating poly block and pin.

**Laboratory Load** – 100 pounds (45.36kg) A static of 100 pounds (45.35kg) (using ten 10-pound [4.54kg] sandbags per Section No. 3.1) shall be uniformly distributed in the drawer. Measure force




Figure 11. Drawer Cycling Mechanism Test Configuration

required to activate the drawer. Operate from a closed position to within  $\frac{1}{4}$ " (6.35mm) of full extension for 50,000 cycles at a rate not to exceed 10 cycles per minute.

**Heavy Duty Laboratory Load** – 150 pounds (68.04kg) A static of 150 pounds (68.04kg) (using fifteen 10-pound [4.54kg] sand bags per Section No. 3.1) shall be uniformly distributed in the

drawer. Measure force required to activate the drawer. Operate from a closed position to within  $\frac{1}{4}$ " (6.35mm) of full extension for 50,000 cycles at a rate not to exceed 10 cycles per minute.

### 6.5.3 Acceptance Level

The drawer shall operate freely without evidence of dragging, rubbing or binding. The force required to open and close loaded drawer shall not be greater than 8 pounds (3.63kg) to activate hardware.\*

*\*The American's with Disabilities Act (ADA) requires a force no greater than five pounds to activate hardware. The load rating in this document is intended only for testing conditions where loads challenge the durability of the hardware. Under actual conditions, drawer loading should be reduced to levels that result in compliance with ADA as applicable.*

## 7.0 Shelving

### 7.1 Description of Test Unit

Metal shelving shall be tested using the following procedure. The shelves to be tested are described in Sect. 4.1 and 9.1 "Description of Test Cabinet". Shelves on both base and wall units shall be tested to this section.

### 7.2 Shelf Load Test

#### 7.2.1 Purpose of Test

This test will demonstrate the ability of a shelf and its mounting hardware to support normal laboratory loads.

#### 7.2.2 Test Procedure

A shelf shall be mounted in a manner in which it is designed. Measure the distance from the underside of the shelf to a reference point located on the center line of the shelf,  $1/2$ " from the front edge of the shelf. Use shot or sand bags weighing 10 pounds (4.535 Kg) each. Unless otherwise specified, load the shelf uniformly to 40 pounds (18.14 kg) per square foot of shelf area to a maximum of 200 pounds (90.71 Kg). Measure

the deflection of the shelf by measuring the distance to the reference point and calculating the difference between the two measurements. Record data and remove the load.

#### 7.2.3 Acceptance Level

The allowable maximum deflection of a shelf is  $1/180$  of the span and not in excess of  $.25$ " (6.35mm). The following formula may be used to calculate the approximate deflection expected from a uniformly distributed load:

$$D(\text{max.}) = 5W L^3 / 384 EI$$

WHERE:

D = Deflection in inches (Maximum  $1/180$  span, not to exceed  $.25$ " (6.35mm)).

W = (Design Load) x (Shelf Depth in Inches) x (Shelf Span in Inches) (Design Load = 40 pounds (18.14 Kg) / square foot divided by 144)

"W" shall not exceed 200 pounds (90.72 Kg).

L = Span between supports in inches

E = Modulus of Elasticity Steel =  $29 * 10^6$  psi  
1-M-2

I = Cross section moment of inertia.

## 8.0 Cabinet Surface Finish Tests

### 8.1 Chemical Spot Test

Users should consider the chemical and staining agents that might be used near the laboratory casework. Common guidelines can be found by referring to: The casework manufacturer printed data for chemical and stain resistance. Because chemical and stain resistance is affected by concentration, time, temperature, humidity, housekeeping and other factors, it is recommended that users test samples in their actual environment with the substances they use.

#### 8.1.1 Purpose of Test

The purpose of the chemical spot test is to

evaluate the resistance a finish has to chemical spills.

Note: Many organic solvents are suspected carcinogens, toxic and/or flammable. Great care should be exercised to protect personnel and the environment from exposure to harmful levels of these materials.

### 8.1.2 Test Procedure

Provide 2" x 2" (50.8mm x 50.8mm) 18 gauge CRS test sample with between 2 and 4 mils of the manufacturer's standard paint finish applied. The sample to be tested for chemical resistance as described herein.

Place panel on a flat surface, clean with soap and water and blot dry. Condition the panel for 48-hours at 73° +/- 3°F (23° +/- 2°C) and 50 +/- 5% relative humidity or the currently accepted guideline set by ASTM. Test the panel for chemical resistance using forty-nine different chemical reagents by one of the following methods.

**Method A** - Test volatile chemicals by placing a cotton ball saturated with reagent in the mouth of a 1-oz. (29.574cc) bottle and inverting the bottle on the surface of the panel.

**Method B** - Test non-volatile chemicals by placing five drops of the reagent on the surface of the panel and covering with a 24mm watch glass, convex side down.

For both of the above methods, leave the reagents on the panel for a period of one hour. Wash off the panel with water, clean with detergent and naptha, and rinse with deionized water. Dry with a towel and evaluate after 24-hours at 73° +/- 3°F (23° +/- 2°C) and 50 +/- 5% relative humidity, or the currently accepted guideline set by ASTM using the following rating system.

**Level 0 - No detectable change.**

**Level 1 - Slight change in color or gloss.**

**Level 2 - Slight surface etching or severe staining.**

**Level 3 - Pitting, cratering, swelling, or erosion of coating. Obvious and significant deterioration.**

Note: Percentages are by volume.

Test No.	Chemical Reagent	Test Method
1.	Acetate, Amyl	A
2.	Acetate, Ethyl	A
3.	Acetic Acid, 98%	B
4.	Acetone	A
5.	Acid Dichromate, 5%	B
6.	Alcohol, Butyl	A
7.	Alcohol, Ethyl	A
8.	Alcohol, Methyl	A
9.	Ammonium Hydroxide, 28%	B
10.	Benzene*	A
11.	Carbon Tetrachloride	A
12.	Chloroform	A
13.	Chromic Acid, 60%	B
14.	Cresol	A
15.	Dichloracetic Acid	A
16.	Dimethylformamide	A
17.	Dioxane	A
18.	Ethyl Ether	A
19.	Formaldehyde, 37%	A
20.	Formic Acid, 90%	B
21.	Furfural	A
22.	Gasoline	A
23.	Hydrochloric Acid, 37%	B
24.	Hydrofluoric Acid, 48%	B
25.	Hydrogen Peroxide, 30%	B
26.	Iodine, Tincture of	B
27.	Methyl Ethyl Ketone	A
28.	Methylene Chloride	A
29.	Monochlorobenzene*	A
30.	Naphthalene	A
31.	Nitric Acid, 20%	B
32.	Nitric Acid, 30%	B
33.	Nitric Acid, 70%	B
34.	Phenol, 90%	A
35.	Phosphoric Acid, 85%	B
36.	Silver Nitrate, Saturated	B
37.	Sodium Hydroxide, 10%	B
38.	Sodium Hydroxide, 20%	B
39.	Sodium Hydroxide, 40%	B
40.	Sodium Hydroxide Flake	B
41.	Sodium Sulfide Saturated	B
42.	Sulfuric Acid, 33%	B
43.	Sulfuric Acid, 77%	B
44.	Sulfuric Acid 96%	B
45.	Sulfuric Acid, 77% & Nitric Acid, 70% equal parts	B
46.	Toluene	A
47.	Trichloroethylene	A
48.	Xylene	A
49.	Zinc Chloride, Saturated	B

\*If the use of this chemical is permitted by law in the country where the testing is being performed.

### **8.1.3 Acceptance Level**

Results will vary from manufacturer to manufacturer due to differences in finish formulations. Laboratory grade finishes shall result in no more than four (4) Level 3 conditions. Individual test results, for the specified 49 reagents, will be verified with the established third party, independent SEFA 8 test submittal form. Suitability for a given application is dependent upon the chemicals used in a given laboratory.

## **8.2 Hot Water Test**

### **8.2.1 Purpose of Test**

The purpose of this test is to insure the surface is resistant to hot water.

### **8.2.2 Test Procedure**

Hot water (190°F to 205°F [88°C to 96°C]) shall be allowed to trickle (with a steady stream and at a rate of not less than 6 ounces [177.44cc] per minute) on the finished surface, which shall be set at an angle of 45°, for a period of five minutes.

### **8.2.3 Acceptance Level**

After cooling and wiping dry, the finish shall show no visible effect from the hot water.

## **8.3 Impact Test**

### **8.3.1 Purpose of Test**

The purpose of this test is to evaluate the ductility of the coating.

### **8.3.2 Test Procedure**

An 18 gauge CRS sample panel shall measure approximately 14" x 24" (355.6mm x 609.6mm). The panel shall have between 2 and 4 mils of the manufacturer's standard paint finish applied.

Position the panel on a smooth concrete floor. A one-pound ball (approximately 2" [50.8mm] in diameter) shall be dropped from a distance of 12" (304.8mm) onto a flat horizontal surface.

### **8.3.3 Acceptance Level**

There shall be no visual evidence to the naked eye of cracks or checks in the finish due to impact.

## **8.4 Paint Adhesion Test**

### **8.4.1 Purpose of Test**

The paint adhesion test is used to determine the bond of the coating to steel.

### **8.4.2 Test Procedure**

Using one of the samples described in section 10.1.2, perform the following test.

This test is based on ASTM D3359-02 "Standard Test Methods for Measuring Adhesion by Tape Test1 – Test Method B". Two sets of six parallel lines 2mm apart shall be cut with a razor blade to intersect at right angles thus forming a grid of 25 squares. The cuts shall be made just deep enough to go through the coating, but not into the substrate. Brush the grid area lightly with a soft brush, and then place a piece of tape over the grid. Rub the tape firmly with the eraser of a pencil to ensure good contact. Remove the tape by rapidly pulling it back upon itself as close to an angle of 180° as possible.

### **8.4.3 Acceptance Level**

A 4B rating or better (ninety five percent or more of the grid area shall show finish intact).

## **8.5 Paint Hardness Test**

### **8.5.1 Purpose of Test**


The paint hardness test is used to determine the resistance of the coatings to scratches.

### **8.5.2 Test Procedure**

This test is based on ASTM D3363-0 "Standard Test Method for Film Hardness by Pencil Test1". Using one of the samples described in section 10.1.2, perform the following test.

Clip a corner of the sample at 45° exposing a raw metal edge. Place the sample on a raw metal base plate so that the exposed metal edge of the sample makes contact with the turned up side of the base plate (see Figure 12).

Remove approximately 6mm of wood from a 4H pencil, being careful to leave an undisturbed smooth cylinder of lead. Holding the pencil at an angle of 90° to an abrasive paper, rub the lead against the paper maintaining an exact angle of 90° until a flat smooth and circular cross section is obtained. On the other end of the pencil remove approximately 13mm of wood from one half of the pencil (see Figure 13). Install the pencil into a Sheen model 720N Pencil Scratch Hardness Tester. Connect a continuity meter to the base plate and to the top of the pencil, being sure to make good



contact with the exposed portion of the lead.

Following the manufacturers instructions place the tester on the surface of the test sample and push it forward approximately 13mm. Rotate the pencil 90° in the holder and repeat the test to one side of the first test. Repeat this two more times for a total of four tests, each with a different quadrant of the pencil lead.



**Fig 13. 4H Pencil Configuration**

### 8.5.3 Acceptance Level

The paint finish shall withstand the abrasion of a 4H pencil without penetrating through to the substrate and completing a continuous circuit.

### 8.6 Dart Impact Test

**Not Applicable to Metal Casework.**

### 8.7 Edge Delaminating Test

**Not Applicable to Metal Casework.**

### 8.8 Edge Impact Test

**Not Applicable to Metal Casework.**

### 8.9 Wear Resistance (Abrasion) Test

**Not Applicable to Metal Casework.**

## 9.0 Wall, Counter Mounted, and Tall Units

### 9.1 Description of Test Cabinet

Evaluation shall be conducted on a wall mounted cabinet with nominal dimensions as follows: 48" (1,219.2mm) +/- 1" wide, 30" (762mm) +/- 1" high, and 12" (304.8mm) +/- 1" deep. The wall cabinet shall be manufactured to manufacturers' standard construction and practices. The wall cabinet shall have two (2) doors and two (2) shelves. Shelves shall be evaluated per Section 7.0 (Shelving). The unit and shelves shall be mounted in a manner recommended by the manufacturer. A visual examination shall be conducted to verify that the configuration and installation comply with these conditions. Discontinue evaluation if unit is not in compliance or if malfunction is noted.


### 9.2 Wall Cabinet Load Test

#### 9.2.1 Purpose of Test

The wall mounted load test will demonstrate the strength of the back of the wall cabinet as well as the joinery of the cabinet and function of doors when the unit is subjected to loads normally expected for laboratory furniture.

**Fig 14. Wall Mounted Cabinet**

**Description of Test Cabinet**



### 9.2.2 Test Procedure

The unit and shelves shall be mounted to a wall in a manner recommended by the manufacturer. Using sand or shot bags weighing 10 pounds (4.55 Kg) each, load cabinet bottom, each shelf, and top uniformly with 40 pounds (18.18 Kg) per square foot to a maximum of 200 pounds (90.91 Kg) each. Maximum load to any cabinet shall not exceed 600 pounds (272.73 Kg) with the total load being distributed as 200 pounds (72.57 Kg) on the bottom, 160 pounds (72.57 KG) on the top and 140 pounds (53.50 Kg) per shelf (2 shelves required). Test to be performed with doors closed.

### 9.2.3 Acceptance Level

With weights in place, after a period of 24 hours, operate doors through full travel to verify normal operation of doors. Remove weights and operate doors to verify normal operation. Verify that there is no significant permanent deflection of cabinet top, cabinet back, cabinet bottom, or shelves. After weights are removed, the cabinet shall show no permanent damage to the cabinet, cabinet bottom, or shelves.

## 10.0 Tables

### 10.1 Description of Test Unit


The table for evaluation shall be a standing height, four legged, freestanding table frame. The table frame shall be nominally 60" +/- 1" (1,524mm) long, 24" +/- 1" (609.6mm) deep, and 36" +/- 1",

(914.4mm) high (see Figure 15). Leg and apron size and construction shall be to manufacturer's specification. A top of 1" (25.4mm) thick 37 - 50 pcf medium density fiberboard shall be supplied and mounted on the table by the testing agency in a manner recommended by the manufacturer. The top dimensions will be such that it will overhang the cabinet perimeter by 1". Its weight shall be included in the test as live load.

A very large range of styles and designs can represent tables frames. Products inclusive in this section of testing are: Free Standing Tables, Desks, Aprons mounted between two fixed areas such as a wall or Casework, Mobile Tables (Free Standing Tables on wheels or casters), Mobile Under Counter Units, Mobile Workstations, Adjustable Tables, Modular Tables, C-Frame Tables, L-Frame Tables, J-Frame Tables, and Tables for systems furniture. These table systems can all be classified as one of three types of tables; Fixed, Free Standing, and mobile. See Figure 15.

### 10.2 Table Static Load

**Fig 15. Description of Test Table**



#### 10.2.1 Purpose of Test

This test will challenge the table components to loads that are used in the laboratory.

#### 10.2.2 Test Procedure

Load the table top by using solid steel bars (per Section 3.1), each weighing 50 pounds (22.68 Kg), stacked evenly and spaced per Figure 16. These evenly distributed loads should be no less than 600 pounds (272.16 Kg) for free standing tables. Include the weight of the working surface as live load.

### 10.2.3 Acceptance Level

No structural breakage shall result from application of the load. With the full load, the apron rails




Fig 16. Table Static Test Configuration

shall not deflect more than 1/360 of the span of the table and not to exceed 1/8" (3.175mm). In the case of a table with a drawer, the deflection of the rail shall not interfere with the function of the drawer. After the load is removed, inspect the table for structural damage.

## 10.3 Table Racking

### 10.3.1 Purpose of Test

This test will demonstrate the structural integrity of the table construction when subjected to a racking load. Most racking failures occur upon dragging an unloaded table across a floor. The ability of a table to resist a racking load will indicate less damage to the structure. The following tests were based on and adapted from ANSI/BIFMA X5.5-1989 American National Standard for Office Furnishings "Desk Products-Tests." Adjustments have been made to better accommodate the specific applications of tables used in laboratories.

### 10.3.2 Test Procedure

The table shall have a common two-by-four wood rail clamped on the centerline of the top parallel to the ends of the table. The table shall then be positioned at 45°, with one pair of legs on the floor and the other raised and supported (see Figure 17). To prevent the table from tipping over, attach a cable to the end rail of the table and to

the wall. The attachment of the cable at the wall must be equal to or less than the height of the attachment at the table. The table shall then have 250 pounds (113.398 Kg) of weight (five 50-pound (22.679 Kg) bars) placed on its top and held in place by the two-by-four wood rail. The unit shall remain in this position for seventy-two hours. The unit shall be lowered without shock to the leveled surface and the general operation of the drawers shall be evaluated.




Fig 17. Table Racking Test Configuration

### 10.3.3 Acceptance Level

When returned to normal position the operation of the table shall be normal, and there will be no permanent damage

## 11.0 Mobile Casing

### 11.1 Description of Test Cabinet

Test cabinet to have 3 equal drawers on the face and finished both sides and back. The top to have an integral finished worksurface or an applied MDF worksurface not to exceed 1" in thickness nor surpass 1" in overhang beyond the cabinet on all 4 sides. The test cabinet to measure 24" wide x 22" deep x 30" high (with casters). The inside depth of the drawers shall be no less than 18"(457.2mm). The drawer in the full open position shall expose no less than 2/3 of the drawer interior.




Figure 1. Description of Test Mobile Base Cabinet

signs of permanent deformation to front rail, cabinet joinery, doors, or drawers.




Figure 2. Static Stability Test Configuration

## 11.2 Static Stability Test

### 11.2.1 Purpose of Test

The static stability test will challenge the load bearing capability of the mobile base cabinet construction. This test will demonstrate the ability of the mobile base cabinet to support heavy applied loads without overturning.

### 11.2.2 Test Procedure

Verify that the cabinet is level and supported only by the casters.

Casters shall be positioned with all casters turned rearward.

Extend the top drawer to fully open.

Manufacturers who choose to test their cabinet without Interlocking Hardware must test and pass the Static Stability Test with all movable elements positioned in their least stable condition. Load the mobile base cabinet top drawer by using 50 pounds (22.68 Kg) of solid steel bars or shot bags evenly distributed within the fully extended top drawer. After five minutes, unload the cabinet.

### 11.2.3 Acceptance Level

The cabinet shall not tip or overturn at any point. Operation of movable elements shall be normal under condition of test load. There shall be no signs of permanent deformation to front rail, cabinet joinery, doors or drawers.

## 11.3 Static Load Test

### 11.3.1 Purpose of Test

The cabinet load test will challenge the structural integrity and load bearing capability of the mobile base cabinet construction. This test will demonstrate the ability of the cabinet to support and operate under heavy applied loads.

### 11.3.2 Test Procedure

All moveable elements shall be in their closed position for this test.

Verify that the cabinet is level and supported only by the casters.

Load the cabinet top by using 250 pounds (113.4 Kg) of solid steel bars or shot bags evenly distributed.




Figure 3. Static Load Test Configuration

Each drawer shall be loaded with 50 pounds (22.68 Kg) of solid steel bars or shot bags evenly distributed within each closed drawer.

### 11.3.3 Acceptance Level

Operation of movable elements shall be normal under condition of test load. There shall be no signs of permanent deformation to front rail, cabinet joinery, or movable elements.

## 11.4 Rolling Stability Test

### 11.4.1 Purpose of Test

This test will demonstrate the durability of the caster, caster attachment and the cabinet's ability to withstand travel over a threshold.

### 11.4.2 Test Procedure

Prior to conducting the test, a static load of 50 pounds (22.68kg) (using 5 ten 10-pound (4.54kg) sandbags per Section No. 3.1) shall be evenly distributed in each drawer. Secure a threshold (per Section No. 3.1) to the floor or blocked off from a wall far enough for the cabinet to completely travel over. Starting at the threshold, place a line of masking tape on the floor, every 0.8 meters,

perpendicular to the threshold, a minimum of 8m of total length, if possible. The tape can also be placed every 0.4 meters with a pace of 120 beats per minute to achieve 0.8m/second. Using a metronome or smartphone app to make one click/beat every second (or alternatively 120 beats per minute) ensures the cabinet is traveling at 0.8m/second. Push the cabinet at its top, so that it is traveling over the masking tape at the same




Figure 4. Rolling Stability Test Configuration

point every beat. The side of the cabinet shall be parallel to the direction of travel and moveable elements shall face the person pushing the cabinet. Continue to push the cabinet over the threshold at this pace.

### 11.4.3 Acceptance Level

The cabinet shall travel up and over the threshold without permanent damage or overturn.

## Endnotes

1This format has been adapted from the BIFMA American National Standard format, X5.5 - 1989.

2Ibid. p 8.

3Ibid. pp 10-26.

4The Concise American Heritage Dictionary, (Boston: Houghton Mifflin Company, 1969), p. 38.

5Architectural Woodwork Institute, Architectural Woodwork Quality Standards Illustrated, 7th Edition Version 1.0, 1997, p A-563.

6E. Paul DeGarmo, Materials and Process in Manufacturing, 5th Edition, (New York: MacMillan Publishing Co., Inc.1979), p 423.

7A. Merriam-Webster, Webster's Ninth New Collegiate Dictionary, (Massachusetts: Merriam-Webster Inc. 1988), p 381.

8U.S. Forest Products Laboratory, Wood Engineering Handbook, (New Jersey: Prentice-Hall, Inc. 1974), p 23-6. 9Architectural Woodwork Quality Standards Illustrated, 7th Edition Version 1.0, p 38.

9Wood Engineering Handbook, p 23-7.

10BIFMA, American National Standard for Office Furnishings, (ANSI/BIFMA X5.5-1983), p 8-9.

11Webster's Ninth New Collegiate Dictionary, 1988, p 980.

12Metals Handbook Committee, Metals Handbook, 8th Edition, Vol.1 "Properties and Selection of Metals" (Ohio: American Society for Metals, 1969), p 408

SEFA 8 Comparison Chart - August 2025

	8-M	8-PH	8-PL	8-P	8-W
<b>Base Cabinet Test Unit</b>	48" W x 35" H x 22" D	48" W x 36" H x 22" D	48" W x 36" H x 22" D	48" W x 36" H x 22" D	48" W x 36" H x 22" D
<b>4.2 Cabinet Load Test</b>	2000 lbs for 10 minutes	2000 lbs for 24 hours	2000 lbs for 24 hours	1600 lbs for 10 minutes	2000 lbs for 24 hours
<b>4.3 Cabinet Concentrated Load Test</b>	200 lbs	200 lbs	200 lbs	160 lbs	200 lbs
<b>4.4 Cabinet Torsion</b>	200 lbs for 24 hours	200 lbs for 24 hours	200 lbs for 24 hours	160 lbs for 15 minutes	200 lbs for 24 hours
<b>4.5 Cabinet Submersion</b>	N/A	24" water for 4 hours	2" water for 24 hours/48 hour dry	24" water for 4 hours	2" water for 4 hours
<b>4.6 Spill Containment</b>	N/A	N/A	N/A	Fill with water to 1/8" of top of bottom rail - No leakage	N/A
<b>5.0 Door Hinge Test</b>	200 lbs	200 lbs	160 lbs	120 lbs	200 lbs
<b>5.2 Door Impact Test</b>	20 lbs = 240 in/lb impact	N/A	N/A	10 lbs = 190 in/lb impact	N/A
<b>5.3 Door Cycle Test</b>	100,000 cycles	100,000 cycles	100,000 cycles	50,000 cycles	100,000 cycles
<b>6.1 Drawer Static Test</b>	150 lbs	150 lbs	150 lbs	120 lbs	150 lbs
<b>6.2 Drawer and Door Pull Test</b>	50 lbs for 15 seconds	N/A	N/A	40 lbs	N/A
<b>6.3 Drawer Impact Test</b>	10 lbs / 24" High	10 lbs / 24" High	10 lbs / 24" High	8 lbs / 24" High	10 lbs / 24" High
<b>6.4 Drawer Internal Rolling Impact</b>	10 lbs / 13" High	10 lbs / 13" High	10 lbs / 13" High	10 lbs / 13" High	10 lbs / 13" High
<b>6.5 Drawer Cycle Test</b>	100 lbs / 50,000 cycles	75 lbs / 50,000 cycles	100 lbs / 50,000 cycles	10 lbs / 25,000 cycles	75 lbs / 50,000 cycles
<b>7.2 Shelf Load Test</b>	40 lbs/SF / 200 lb max/ 0.25" Def	40 lbs/SF / 200 lb max/ 0.25" Def	40 lbs/SF / 200 lb max/ 0.25" Def	10 lbs/SF / 75 lb max/ 0.25" Def	40 lbs/SF / 200 lb max/ 0.25" Def
<b>8.1 Chemical Spot Test</b>	No more than four Level 3	No more than four Level 3	No more than four Level 3	No Level 3. Additional chemical resistance data available.	No more than four Level 3
<b>8.2 Hot Water Test</b>	190 to 205 degree for 5 min	190 to 205 degree for 5 min	ANSI/NEMA LD 3-2005 Para 3.5 Boiling Water Res - No change in color or surface finish.	190 to 205 degree for 5 min	190 to 205 degree for 5 min
<b>8.3 Impact Test</b>	1 lb ball / 12" High	N/A	ANSI/NEMA LD 3-2005 Para 3.8 Ball Impact Res. - Min of 50"	N/A	N/A
<b>8.4 Paint Adhesion Test</b>	4B Rating or better	N/A	N/A	N/A	N/A
<b>8.5 Paint Hardness Test</b>	4H Pencil w/o penetration	N/A	N/A	N/A	N/A
<b>8.6 Dart Impact Test:</b>	N/A	N/A	ANSI/NEMA LD 3-2005 Para 3.9 Dart Impact Resistance - Min of 20"	N/A	N/A
<b>8.7 Edge Delamination Test</b>	N/A	N/A	Peel value greater than 18.5 lbs/in	N/A	N/A
<b>8.8 Edge Impact Test</b>	N/A	N/A	No signs of damage after impact	N/A	N/A
<b>8.9 Wear Resistance Test</b>	N/A	N/A	ANSI/NEMA LD 3-2005 Para 3.13 Wear Resistance	N/A	N/A
<b>Wall Mounted Test Unit</b>	48" W x 30" H x 12" D	48" W x 30" H x 12" D	48" W x 30" H x 12" D	48" W x 30" H x 12" D	48" W x 30" H x 12" D
<b>9.2 Wall Cabinet Load Test</b>	200 lb max/shelf / 600 lb max	200 lb max/shelf / 600 lb max	200 lb max/shelf / 600 lb max	40 lb max/shelf / 480 lb max	200 lb max/shelf / 600 lb max
<b>Table Test Unit</b>	60" W x 36" H x 24" D	N/A	60" W x 36" H x 24" D	60" W x 36" H x 24" D	60" W x 36" H x 24" D
<b>10.2 Table Static Load</b>	600 lbs / 1/8" Deflection	N/A	300 lbs mobile, 600 lbs free standing, 2000 lbs fixed / 1/8" Deflection	300 lbs / 1/8" Deflection	300 lbs mobile, 600 lbs free standing, 2000 lbs fixed / 1/8" Deflection
<b>10.3 Table Racking</b>	250 lbs	N/A	250 lbs	N/A	250 lbs
<b>Mobile Test Unit</b>	24" W x 22" D x 30" H w/casters	24" W x 22" D x 30" H w/casters	24" W x 22" D x 30" H w/casters	24" W x 22" D x 30" H w/casters	24" W x 22" D x 30" H w/casters
<b>11.2 Static Stability Test</b>	50 lbs 5 Mins / No deformation	50 lbs 5 Mins / No deformation	50 lbs 5 Mins / No deformation	50 lbs 5 Mins / No deformation	50 lbs 5 Mins / No deformation
<b>11.3 Static Load</b>	250 lbs / top; 50 lbs per drawer no deformation	250 lbs / top; 50 lbs per drawer no deformation	250 lbs / top; 50 lbs per drawer no deformation	250 lbs / top; 50 lbs per drawer no deformation	250 lbs / top; 50 lbs per drawer no deformation
<b>11.4 Rolling Stability</b>	50 lbs per drawer - no perm damage or overturn	50 lbs per drawer - no perm damage or overturn	50 lbs per drawer - no perm damage or overturn	50 lbs per drawer - no perm damage or overturn	50 lbs per drawer - no perm damage or overturn

## LABORATORY FURNITURE CERTIFICATE OF PERFORMANCE

\_\_\_\_ certifies that its laboratory furniture identified as  
(Company Name)

\_\_\_\_, has been tested in conformance with the full requirements  
(Test Unit)

of the **SEFA 8-M-2025 Standard**. Testing was performed by a SEFA-approved Independent Third Party Test Lab with results noted below.

Full documentation of the test results is available upon request in a bound report that includes a detailed description of the test unit and procedures, witnesses results and appropriate drawings or photographs of the test unit and procedures.

TEST	TEST RESULTS PASS/FAIL	TEST	TEST RESULTS PASS / FAIL	TEST	TEST RESULTS PASS / FAIL
4.2		6.2		8.2	
4.3		6.3		8.3	
4.4		6.4		8.4	
5.1	@200 lbs.	6.5	@ 100 lbs.	8.5	
5.2		6.5	@ 150 lbs.	9.2	
5.3		7.2	Deflection Measured	10.2	
6.1		8.1	See Attached Form	10.3	
COMPANY INFORMATION			TEST SUPERVISOR INFORMATION		
Name:			Name:		
Address:			Title:		
			Signature:		
Telephone:		COMPANY OFFICER INFORMATION			
Fax:		Name:			
		Title:			
Date:		Signature:			

## CHEMICAL RESISTANCE TESTING – 8-M-2025

Date of Test: \_\_\_\_\_ Sample Description: \_\_\_\_\_

Type of Material Coated: \_\_\_\_\_ Coating Type: \_\_\_\_\_

Rating Scale: Level 0 – No Detectable Change

Level 1 – Slight Change in Color or Gloss

Level 2 – Slight Surface Etching or Severe Staining

Level 3 – Pitting, Cratering, Swelling, Erosion of Coating. Obvious and Significant Deterioration

Test No.	Chemical Reagent	Rating	Comments
1.	Acetate, Amyl		
2.	Acetate, Ethyl		
3.	Acetic Acid, 98%		
4.	Acetone		
5.	Acid Dichromate, 5%		
6.	Alcohol, Butyl		
7.	Alcohol, Ethyl		
8.	Alcohol, Methyl		
9.	Ammonium Hydroxide, 28%		
10.	Benzene*		
11.	Carbon Tetrachloride		
12.	Chloroform		
13.	Chromic Acid, 60%		
14.	Cresol		
15.	Dichloroacetic Acid		
16.	Dimethylformamide		
17.	Dioxane		
18.	Ethyl Ether		
19.	Formaldehyde, 37%		
20.	Formic Acid, 90%		
21.	Furfural		
22.	Gasoline		
23.	Hydrochloric Acid, 37%		
24.	Hydrofluoric Acid, 48%		
25.	Hydrogen Peroxide, 30%		
26.	Iodine, Tincture of		
27.	Methyl Ethyl Ketone		
28.	Methylene Chloride		
29.	Mono Chlorobenzene*		
30.	Naphthalene		
31.	Nitric Acid, 20%		
32.	Nitric Acid, 30%		
33.	Nitric Acid, 70%		
34.	Phenol, 90%		
35.	Phosphoric Acid, 85%		
36.	Silver Nitrate Saturated		
37.	Sodium Hydroxide 10%		
38.	Sodium Hydroxide 20%		
39.	Sodium Hydroxide 40%		
40.	Sodium Hydroxide Flake		
41.	Sodium Sulfide Saturated		
42.	Sulfuric Acid, 33%		
43.	Sulfuric Acid, 77%		
44.	Sulfuric Acid, 96%		
45.	Sulfuric Acid 77% & Nitric Acid 70% equal parts		
46.	Toluene		
47.	Trichloroethylene		
48.	Xylene		
49.	Zinc Chloride, Saturated		

\*IF THE USE OF THIS CHEMICAL IS PERMITTED BY LAW IN THE COUNTRY WHERE THE TESTING IS BEING PERFORMED.

TEST PERFORMED BY: \_\_\_\_\_

DATE: \_\_\_\_\_

